
 STATE PUBLIC HEALTH LABORATORY, PUNE			
Dy Director tele No. 26330509 (P) Office Tele No. 26330225 (O)		Cantonment water works campus, Near Saint Mary Church, Staveley road, Pulgate, Pune-411 001 (MH) INDIA Email ID : sphlmis@gmail.com , statehealthlab@gmail.com website : arogya.maharashtra.gov.in			
HEALTH SERVICES:		No.SPHLPUNE/Desk-80/Bact.Section/water analysis report/ 1131 / 2025. Date : 28/07/2025			

Bacteriological Report of water Sample

Sender's Name	City International School, Pimpri-Morwadi Road, Pimpri, Pune-411018.
Sendr's letter No. & date	--/ 23-07-2025
Lab. Reference No.	197 / 1052
Date of sample collection	23/07/2025
Date of sample received	23/07/2025
Analysis start date	23/07/2025

	Sample Description	Bacteriological Analysis result			
		Most Probable Number of bacteria found per 100 ml of Water Sample			
		Coliforms	Thermotolerant Coliforms	<u>E.coli</u>	Conclusion
1.	City International School Morwadi Road, Pimpri, Pune – Filter (RO)	0	-	-	Potable


Remark: If water sample found non-potable, it can be used for drinking purposes after proper treatment and ascertaining its bacteriological quality for potability by retesting.

Note: Above sample/samples is/are not collected by this laboratory and result is/are as per submitted sample/samples.

Fee Rs. 340/-

Receipt No. : 7760838

Date : 23/07/2025


Chief Bacteriologist
State Public Health Laboratory, Pune